

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
 Kingsgrove, NSW 2208, Australia



| PRODUCT INFORMATION | | |
|---------------------|----------------------|-------|
| BRAND | MODEL | SKU |
| Ektor | EV-LED FIRE-SM-PRO-B | 01690 |

| COMPLIANCE | |
|-------------|--------------------------------------------------------------------------------------------------------|
| 2293 Report | WTF22F05101757N |
| Standards | AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3 |

| OPERATIONAL INFORMATION | |
|-------------------------|--------------------|
| IP Rating | IP20 |
| Working Temp Range | 0 to 40 °C |
| Input voltage | 230Vac |
| Input Frequency | 50 Hz |
| Electrical Rating | Class II |
| Driver Type | DALI DT1 Emergency |
| Product Type | EM LIGHT NETWORK |

| EMERGENCY INFORMATION | |
|--------------------------|----------------|
| Emergency Mode | Non-Maintained |
| Emergency Duration | 90 mins |
| Emergency Classification | C0:D80 C90:D80 |
| Replacement Battery Code | 01303 |

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature: 