## evolt PEARL PROFESSIONAL IP65 - SER II COMPLIANCE

## **DECLARATION OF COMPLIANCE FOR LUMINAIRES**

Issuer:	Evolt Pty Ltd
Address:	U5/105a Vanessa Street
	Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION			
BRAND	MODEL	SKU	
Ektor	EV-PEARL-PRO-IP65-EM	11963	

COMPLIANCE		
2293 Report	WTF22F03034546N	
Standards	AS/NZS 60598.1	
	AS 60598.2.22	
	AS/NZS 61347.1	
	AS/NZS 61347.2.13	
	AS CISPR 15	
	AS/NZS 2293.3	
	IEC 62386-102	
	IEC 62386-103	

OPERATIONAL INFORMATION		
IP Rating	IP65	
Working Temp Range	0 to 40 °C	
Input voltage	230Vac	
Input Frequency	50 Hz	
Electrical Rating	Class I	
Driver Type	DALI DT1 and DT8 Dimmable	
Product Type	EM LIGHT NETWORK	

EMERGENCY INFORMATION		
Emergency Mode	Maintained	
Emergency Duration	90 mins	
Emergency Classification	C0:D40, C90:D40	
Replacement Battery Code	01302	

## **DECLARATION OF COMPLIANCE**

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director

Date: 05/01/2022

Signature:



SDoC Document ID: PEARL-PROFESSIONAL-IP65---SER-IL\_11963\_AU | Generated on 28th of April 2024 15:26:27 - Page 1