

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION

| BRAND | MODEL | SKU |
|-------|--------------------------------|-------|
| Ektor | EV-UMBRA-ADV-IP65-600-EM-S-TRI | 12031 |

COMPLIANCE

| | |
|---------------|---|
| 2293 Report | WTF21F04040295N |
| Safety Report | WTF21F04040286L |
| EMC Report | WTF21F04040288E |
| Certification | SGS-210801-E |
| Standards | AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3 AS/NZS 4268 |

OPERATIONAL INFORMATION

| | |
|--------------------|---------------|
| IP Rating | IP65 |
| Working Temp Range | 0 to 40 °C |
| Input voltage | 230Vac |
| Input Frequency | 50 Hz |
| Electrical Rating | Class I |
| Driver Type | Fixed output |
| Product Type | EM BATTEN SPU |

EMERGENCY INFORMATION

| | |
|--------------------------|-----------------|
| Emergency Mode | Maintained |
| Emergency Duration | 90 mins |
| Emergency Classification | C0:D50, C90:D40 |
| Replacement Battery Code | 01302 |

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature:

J Newell