

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION		
BRAND	MODEL	SKU
Ektor	EV-UMBRA-PRO-IP65-1200-EM-LK	12615

OPERATIONAL INFORMATION	
IP Rating	IP65
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Electrical Rating	Class I
Driver Type	Wireless (IEC62386-104) with DT1 & DT8 Dimmable
Product Type	EM BATTEN NETWORK

COMPLIANCE	
2293 Report	WTF21F09098768N002
Safety Report	WTF21F09098719L
EMC Report	WTF21F09098730E
Certification	GMA-511827
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3 AS/NZS 4268 IEC 62386-102 IEC 62386-103 IEC 62386-104

EMERGENCY INFORMATION	
Emergency Mode	Maintained
Emergency Duration	90 mins
Emergency Classification	C0:D80, C90:D63
Replacement Battery Code	01303

DECLARATION OF COMPLIANCE

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director Date: 05/01/2022

Signature: J Newell