

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
 Kingsgrove, NSW 2208, Australia



### PRODUCT INFORMATION

| BRAND | MODEL                  | SKU   |
|-------|------------------------|-------|
| Ektor | EV-RAZOR-SWING-24M-PRO | 14545 |

### COMPLIANCE

|               |  |
|---------------|--|
| 2293 Report   | 200809PH   |
| Safety Report | WTS19D11077927L  |
| EMC Report    | WTS19S11077953E  |
| Standards     | AS/NZS 60598.1<br>AS 60598.2.22<br>AS/NZS 61347.1<br>AS/NZS 61347.2.13<br>AS CISPR 15<br>AS/NZS 2293.3 |

### OPERATIONAL INFORMATION

|                    |                    |
|--------------------|--------------------|
| IP Rating          | IP20               |
| Working Temp Range | 0 to 40 °C         |
| Input voltage      | 230Vac             |
| Input Frequency    | 50 Hz              |
| Electrical Rating  | Class I            |
| Driver Type        | DALI DT1 Emergency |
| Product Type       | EM EXIT NETWORK    |

### EMERGENCY INFORMATION

|  |                  |
|--|------------------|
| Viewing Distance   | 24 m             |
| Emergency Mode   | Maintained       |
| Emergency Light Source Life  | 31Y/06M          |
| AS2293.3-2018 Projection of Light source life for LED Exit signs (appendix E)<br>Defines the projected time until the surface luminance falls below the minimum required surface luminance for an exit sign. |                  |
| Emergency Duration   | 90 mins          |
| Decal Size   | 300 x 150 mm     |
| Emergency Classification   | C0:E6.3, C90:E16 |
| Replacement Battery Code   | 01300            |

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:** *J Newell*