evolt PEARL PROFESSIONAL IP65 - SER II COMPLIANCE

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer:	Evolt Pty Ltd	
Address:	U5/105a Vanessa Street	
	Kingsgrove, NSW 2208, Australia	



PRODUCT INFORMATION				
BRAND	MODEL	SKU		
Ektor	EV-PEARL-EM-PRO-WP-LK	18142		

COMPLIANCE		
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3	

OPERATIONAL INFORMATION		
IP Rating	IP65	
Working Temp Range	0 to 40 °C	
Input voltage	230Vac	
Input Frequency	50 Hz	
Electrical Rating	Class I	
Driver Type	Wireless (IEC62386-104) with DT1 & DT8 Dimmable	
Product Type	BUNKERS	

EMERGENCY INFORMATION		
Emergency Mode	Maintained	
Emergency Duration	90 mins	
Emergency Classification	C0:D40, C90:D40	
Replacement Battery Code	01302	

DECLARATION OF COMPLIANCE

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director

Date: 05/01/2022

Signature:

Weikell

SDoC Document ID: PEARL-PROFESSIONAL-IP65---SER-IL_18142_AU | Generated on 28th of April 2024 00:24:48 - Page 1

