

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
Kingsgrove, NSW 2208, Australia



## PRODUCT INFORMATION

| BRAND | MODEL        | SKU   |
|-------|--------------|-------|
| Ektor | EV-MERCURY-B | 03136 |

## COMPLIANCE

|             |  |
|-------------|--|
| 2293 Report | LL19845  |
| Standards   | AS/NZS 60598.1<br>AS 60598.2.22<br>AS/NZS 61347.1<br>AS/NZS 61347.2.13<br>AS CISPR 15<br>AS/NZS 2293.3 |

## OPERATIONAL INFORMATION

|                    |                    |
|--------------------|--------------------|
| IP Rating          | IP20               |
| Working Temp Range | 0 to 40 °C         |
| Input voltage      | 230Vac             |
| Input Frequency    | 50 Hz              |
| Electrical Rating  | Class II           |
| Driver Type        | DALI DT1 Emergency |
| Product Type       | EM EXIT NETWORK    |

## EMERGENCY INFORMATION

|                          |              |
|--------------------------|--------------|
| Viewing Distance         | 24 m         |
| Emergency Mode           | Maintained   |
| Emergency Duration       | 90 mins      |
| Decal Size               | 300 x 150 mm |
| Replacement Battery Code | 01300        |

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:** *J Newell*