

MERCURY PRO COMPLIANCE

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd

Address: U5/105a Vanessa Street

Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION				
BRAND	MODEL	SKU		
Ektor	EV-MERCURY-PRO-B-LK	04268		

COMPLIANCE	
2293 Report	WTF23F06142457N001
Safety Report	WTD23D05096929L
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATI	
IP Rating	IP20
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Electrical Rating	Class II
Driver Type	Wireless (IEC62386-104) with DT1
Product Type	EM EXIT NETWORK

EMERGENCY INFORMATION			
Viewing Distance	24 m		
Emergency Mode	Maintained		
Emergency Duration	90 mins		
Decal Size	300 x 150 mm		
Replacement Battery Code	01300		
<u> </u>			

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title:	Managing Director	Date : 05/01/2022	
Signatur	e. Alanast		



SDoC Document ID: MERCURY-PRO_04268_AU | Generated on 27th of April 2024 22:08:23 - Page 1