

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
Kingsgrove, NSW 2208, Australia



## PRODUCT INFORMATION

BRAND	MODEL	SKU
Ektor	EV-UMBRA-ADV-IP65-1200-EM-TRI	12037

## COMPLIANCE

2293 Report	WTF21F04040297N
Safety Report	WTF21F04040286L
EMC Report	WTF21F04040288E
Certification	SGS-210801-E
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

## OPERATIONAL INFORMATION

IP Rating	IP65
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Electrical Rating	Class I
Driver Type	Fixed output
Product Type	EM BATTEN SPU

## EMERGENCY INFORMATION

Emergency Mode	Maintained
Emergency Duration	90 mins
Emergency Classification	C0:D63, C90:D40
Replacement Battery Code	01302

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:**

*J Newell*