

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
Kingsgrove, NSW 2208, Australia



## PRODUCT INFORMATION

BRAND	MODEL	SKU
Ektor	EV-MERCURY-PRO-24M-DA	12561

## COMPLIANCE

2293 Report	WTF23F07164718N
Safety Report	WTD23D05096929L
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

## OPERATIONAL INFORMATION

IP Rating	IP20
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Electrical Rating	Class II
Driver Type	DALI DT1 Emergency
Product Type	EM EXIT NETWORK

## EMERGENCY INFORMATION

Viewing Distance	24 m
Emergency Mode	Maintained
Emergency Light Source Life	>20Y/00M
AS2293.3-2018 Projection of Light source life for LED Exit signs (appendix E) Defines the projected time until the surface luminance falls below the minimum required surface luminance for an exit sign.	
Emergency Duration	90 mins
Decal Size	300 x 150 mm
Emergency Classification	C0:C12.5, C90:C32
Replacement Battery Code	13845

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:** *J Newell*