

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
 Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION		
BRAND	MODEL	SKU
Ektor	EV-QUADRO-EM-PRO	14631

COMPLIANCE	
2293 Report	WTF21F08080345N
Safety Report	WTF21F08080328L
EMC Report	WTF21F08080331E
Certification	GMA-511889
Driver Safety Report	211-14190298-000
Driver Certification	GMA-508278-EA
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS/NZS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION	
IP Rating	IP65
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Electrical Rating	Class I
Driver Type	DALI DT1 and DT8 Dimmable
Product Type	BUNKERS

EMERGENCY INFORMATION	
Emergency Mode	Maintained
Emergency Duration	90 mins
Emergency Classification	C0:D50, C90:D50
Replacement Battery Code	01302

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:** 