

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd

**Address:** U5/105a Vanessa Street  
Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION		
BRAND	MODEL	SKU
Ektor	EV-RAZOR-16M-PRO-LK	18066

COMPLIANCE	
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION	
IP Rating	IP20
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Electrical Rating	Class II
Driver Type	Wireless (IEC62386-104) with DT1
Product Type	EM EXIT NETWORK

EMERGENCY INFORMATION	
Viewing Distance	16 m
Emergency Mode	Maintained
Emergency Light Source Life	18Y/00M
AS2293.3-2018 Projection of Light source life for LED Exit signs (appendix E) Defines the projected time until the surface luminance falls below the minimum required surface luminance for an exit sign.	
Emergency Duration	90 mins
Decal Size	200 x 100 mm
Emergency Classification	C0:C40, C90:C32
Replacement Battery Code	01302

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:**