

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
 Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION		
BRAND	MODEL	SKU
Ektor	EV-RAZOR-24M-PRO-B-LK	18101

COMPLIANCE	
2293 Report	WTF22F11240972N001
Safety Report	211-1417675-100
EMC Report	68.740.17.290.02
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION	
IP Rating	IP20
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Electrical Rating	Class II
Driver Type	Wireless (IEC62386-104) with DT1
Product Type	EM EXIT NETWORK

EMERGENCY INFORMATION	
Viewing Distance	24 m
Emergency Mode	Maintained
Emergency Light Source Life	40Y/06M
AS2293.3-2018 Projection of Light source life for LED Exit signs (appendix E) Defines the projected time until the surface luminance falls below the minimum required surface luminance for an exit sign.	
Emergency Duration	90 mins
Decal Size	300 x 150 mm
Emergency Classification	C0:E12.5, C90:E6.3
Replacement Battery Code	01302

DECLARATION OF COMPLIANCE

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature: 