

AS2293.3 APPENDIX B

DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

Manufacturer: Evolt Pty Ltd
Address: U5/105a Vanessa Street,
 Kingsgrove, NSW 2208, Australia



Last updated: 6 November 2020_v1.0

EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN

ORDER CODE	PRODUCT NUMBER	SKU	QTY
EV-TWINSPOOT-WP-PRO-B Twinspot IP65 Pro Emergency Luminaire, Black	9336462017074	01707	4
EV-TWINSPOOT-WP-PRO-B-LK Lynk Twinspot IP65 Professional Emergency Exit, Black - w/wireless	9336462101995	10199	4

<input checked="" type="checkbox"/> Emergency escape luminaire	<input type="checkbox"/> Centrally supplied
<input type="checkbox"/> Exit sign	<input checked="" type="checkbox"/> Self-contained
<input type="checkbox"/> Maintained	<input checked="" type="checkbox"/> Non-maintained
<input type="checkbox"/> Combined	

TUV SUD (SHENZHEN)

TEST	DESCRIPTION	
Safety Standards	IEC 60598-1:2014 / IEC 60598-2-22:2014 IEC 60598-2-1:1979/AMD1:1987 EN 60598-1:2015 / EN 60598-2-22:2014 EN 60598-2-1:1989 / EN 62493:2015 AS/NZS 60598.2.22:2005 / AS/NZS 60598.2.1:2014+A1:2016 AS/NZS 60598.1:2017+Amdt AS/NZS 2293.3:2018	
Safety Certification	SG PSB-LE-01951M1(CB) N8A0961510039(LVD)	
Safety / Performance Test Report	211-14190100-100(CB) 6814019010002(LVD)	
EMC standards	EN 55015:2013/A1:2015 EN 61000-3-3:2013 AS/NZS CISPR 15: 2011	EN 6100-3-2:2014 EN 61547:2009
EMC Certification	E8A 0961510041	
EMC Test Report	6874019005901	

LIGHTLAB

AS2293 TESTING	DESCRIPTION
Thermal Report	LL1613106T
Photometric Report	LL19410B
Classification	N/A

OPERATIONAL INFORMATION

GENERAL	
Mains Voltage	240V~ 50Hz
Ambient temp.	0 to 40°C
Class	2
Diffuser type	Polycarbonate
BATTERY	
Number of cells	2
Type	LiFePO ₄
Nominal Voltage	6.4 V
Capacity	3000mAh
Part number	1303

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

Title: Managing Director **Date:** 27/10/20

Signature:

ektor.com.au
E: sales@evolt.com.au
P: 1300 4EVOLT (438 658)

evolt
 the electrical evolution

NOTE: This declaration form should be completed in full. The completed form should be considered sufficient to verify compliance with AS 2293.3.

Ektor is dedicated to continuous product improvement. Datasheet is subject to change without notice, E&OE. Images are for illustrative purposes only.