

APPENDIX B

DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

Manufacturer: Evolt Pty Ltd
Address: U5/105a Vanessa Street,
 Kingsgrove, NSW 2208, Australia



Last updated: 4 November 2020_V1.0

EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN			
ORDER CODE	PRODUCT NUMBER	SKU	QTY
EV-PEARL-EM-PRO-WP Pearl Circular IP65 Pro, emergency	9336462018095	01809	4
<input checked="" type="checkbox"/> Emergency escape luminaire	<input type="checkbox"/> Centrally supplied		
<input type="checkbox"/> Exit sign	<input checked="" type="checkbox"/> Self-contained		
<input checked="" type="checkbox"/> Maintained	<input type="checkbox"/> Non-maintained		
<input type="checkbox"/> Combined			

OPERATIONAL INFORMATION	
GENERAL	
Mains Voltage	240V~ 50Hz
Ambient temp.	0 to 40°C
Class	2
Diffuser type	Polycarbonate
BATTERY	
Number of cells	2
Type	LiFePO ₄
Nominal Voltage	6.4 V
Capacity	3000mAH
Part number	1303

X	
TEST	DESCRIPTION
Safety Standards	

Safety Certification

Safety / Performance Test Report

EMC standards

EMC Certification

EMC Test Report

LIGHT LAB	
AS2293 TESTING	DESCRIPTION
Thermal Report	LL1604304T-R01 (PRO)
Photometric Report	LL19188-R01 (PRO)
Classification	D40

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

Title: Managing Director **Date:** 27/10/20

Signature: 

NOTE: This declaration form should be completed in full. The completed form should be considered sufficient to verify compliance with AS 2293.3.

ektor.com.au
E: sales@evolt.com.au
P: 1300 4EVOLT (438 658)

evolt
 the electrical evolution

Ektor is dedicated to continuous product improvement. Datasheet is subject to change without notice, E&OE. Images are for illustrative purposes only.