

## LEDFIRE BASIC COMPLIANCE

## **AS2293.3 APPENDIX B**

## DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

Manufacturer:	Evolt Pty Ltd
Address:	U5/105a Vanessa Street,
	Kingsgrove, NSW 2208, Australia



EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN					
ORDER CODE	PRODUCT NUMBER SKU	QTY			
EV-LEDFIRE-BASIC Ledfire Basic Emergency Luminaire	9336462111901 11190	4			
Emergency escape luminaire	Centrally supplied				
Exit sign	✓ Self-contained				
Maintained	✓ Non-maintained				
Combined					

TUV RHEINLAND (GUANGZHOU)				
TEST	DESCRIPTION			
Safety Standards	IEC 60598-2-22: 2014 IEC 60598-1:2014 EN 60598-2-22: 2014 EN 60598-2-2: 2012 IEC 60598-1:2015 AS/NZS 60598-2-22: 2005 AS/NZS 60598-1:2013 SANS 1464-2-22: 2016 SANS 60598-1:2014			
Safety Certification	DE 2-021604(CB)			
Safety / Performance Test Report	16077795 001			
EMC standards	EN 55015:2013+A1:2015 EN61000-3-2:2014 AS/NZS CISPR 15: 2011	EN 61547:2009 EN61000-3-3:2013		
EMC Certification	16KWE094382E(EMC)			
EMC Test Report	16KWE094382E 16KWE094383C			

LIGHTLAB	
AS2293 TESTING	DESCRIPTION
Thermal Report	LL1621605T LL1804001T
Photometric Report	LL19616 (D25) LL20830 (D25)
Classification	D25

OPERATIONAL INFORMATION				
GENERAL				
Mains Voltage	240V~ 50Hz			
Ambient temp.	0 to 40°C			
Class	2			
Diffuser type	Polycarbonate			
BATTERY				
Number of cells	1			
Туре	LiFePO <sub>4</sub>			
Nominal Voltage	3.2 V			
Capacity	1500mAH			
Part number	1302			

## **DECLARATION OF COMPLIANCE**

Title: Managing Director

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

	11/11	
Signature:	Mewell	

ektor.com.au **E: sales@evolt.com.au** P:1300 4EVOLT (438 658)



**Date:** 27/10/20