

AS2293.3 APPENDIX B

DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

Manufacturer: Evolt Pty Ltd
Address: U5/105a Vanessa Street,
 Kingsgrove, NSW 2208, Australia



Last updated: 17 May 2021_V1.0

EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN		
ORDER CODE	PRODUCT NUMBER	SKU
EV-RAZOR-SM-CORE-24M Slimblade Core Surface-mount Exit light 24M	9336462121238	12123
<input type="checkbox"/> Emergency escape luminaire	<input type="checkbox"/> Centrally supplied	
<input checked="" type="checkbox"/> Exit sign	<input checked="" type="checkbox"/> Self-contained	
<input checked="" type="checkbox"/> Maintained	<input type="checkbox"/> Non-maintained	
<input checked="" type="checkbox"/> Combined		

OPERATIONAL INFORMATION	
GENERAL	
Mains Voltage	230V~ 50Hz
Ambient temp.	0 to 60°C
Class	2
Diffuser type	Polycarbonate
BATTERY	
Number of cells	1
Type	LiFePO ₄
Nominal Voltage	3.2 V
Capacity	1500mAh
Part number	13972

WALTEK (CNAS L9950)	
TEST	DESCRIPTION
Safety Standards	IEC 60598-1:2014+A1:2017 IEC 60598-2-1:1979+A1:1987 IEC 60598-2-22:2014+A1:2017 AS/NZS 2293.3:2018
Safety / Performance Test Report	WTS20D11088194L
EMC standards	AS CISPR 15: 2017
EMC Certification	WTS20S11088187E

LIGHTLAB	
AS2293 TESTING	DESCRIPTION
Thermal Report	WTF20F12097712N
Photometric Report	WTF20F12097712N
Pictogram Report	WTF20F12097712N
Classification	E6.3 E20

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

Title: Managing Director **Date:** 17/05/21

Signature:

ektor.com.au
E: sales@evolt.com.au
 P:1300 4EVOLT (438 658)

Ektor is dedicated to continuous product improvement. Datasheet is subject to change without notice, E&OE. Images are for illustrative purposes only.

NOTE: This declaration form should be completed in full. The completed form should be considered sufficient to verify compliance with AS 2293.3.