

AS2293.3 APPENDIX B

DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

Manufacturer: Evolt Pty Ltd
Address: U5/105a Vanessa Street,
 Kingsgrove, NSW 2208, Australia



Last updated: 27 October 2020_V1.0

EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN			
ORDER CODE	PRODUCT NUMBER	SKU	QTY
EV-5812-EM-CF-LITE LED Emergency Square bulkhead Lite IP65 with c/f sensor Tri Colour	9336462179864	17986	5
<input checked="" type="checkbox"/> Emergency escape luminaire	<input type="checkbox"/> Centrally supplied		
<input type="checkbox"/> Exit sign	<input checked="" type="checkbox"/> Self-contained		
<input checked="" type="checkbox"/> Maintained	<input type="checkbox"/> Non-maintained		
<input type="checkbox"/> Combined			

OPERATIONAL INFORMATION	
GENERAL	
Mains Voltage	220V~ 50Hz
Ambient temp.	5 to 40°C
Class	2
Diffuser type	Polycarbonate
BATTERY	
Number of cells	2
Type	LiFePO ₄
Nominal Voltage	6.4 V
Capacity	1500mAh
Part number	1302

WALTEK(CNAS L9950)	
TEST	DESCRIPTION
Safety Standards	IEC 60598-1:2014+A1:2017 IEC 60598-2-22:2014 IEC 60598-2-1:1979/AMD1:1987 EN 60598-1:2015+A1:2018 / EN 60598-2-22:2014 EN 60598-2-1:1989 / EN 62493:2015 AS/NZS 60598.2.22:2005 AS/NZS 60598.2.1:2014+A1:2016 AS/NZS 60598.1:2017+Amdt
Safety / Performance Test Report	WTS18F12132765X1L
EMC standards	EN 55015:2013/A1:2015 EN 6100-3-2:2014 EN 61000-3-3:2013 EN 61547:2009 AS/NZS CISPR 15: 2011
EMC Test Report	WTS18S12132763E(EMC) WTS18S12132767E(C-tick)

LIGHT LAB	
AS2293 TESTING	DESCRIPTION
Thermal Report	LL1910002T-R01
Photometric Report	LL21784-R01 (Clear) LL21783-R01 (Opal)
Classification	D50

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

Title: Managing Director **Date:** 27/10/20

Signature:

ektor.com.au
E: sales@evolt.com.au
 P:1300 4EVOLT (438 658)

evolt
 the electrical evolution

NOTE: This declaration form should be completed in full. The completed form should be considered sufficient to verify compliance with AS 2293.3.

Ektor is dedicated to continuous product improvement. Datasheet is subject to change without notice, E&OE. Images are for illustrative purposes only.